

MOBILE FOOD VEHICLE/VENDING UNIT (MFVU) Site Setup INSPECTION

Kyle Fire Department
Hays County Emergency Services District No. 5
210 West Moore Street, Kyle, TX 78640
(512) 268-3131 FAX (512) 268-6162

MFVU Permit Number: _____ Annual CoK Permit Fee Paid : _____

OWNER / PROPERTY / MOBILE PROPERTY MANAGEMENT

Business Name: _____ Health Permit # _____

Business Address: _____ City, State, Zip: _____

If MFVU is stored other than Business Address (check): Outside Inside N/A

Storage Address (if applicable): _____ City, State, Zip: _____

Owner's Name: _____ DL #: _____ State: _____

Owner's Address: _____ City, State, Zip: _____

Owner's Ph #: _____ Email: _____

Food Vehicle/Trailer License Plate #: _____ State: _____ Exp. Date: _____

Does the MFVU comply with adopted IFC & NFPA fire/life safety standards: **Yes** No

(Note: checking the bold answer (Yes/No) is correct condition; any non-bold answer is a failure that will require correction.)

LOCATION INSPECTION

Less than 10' to fixed structures, vehicles, or combustibles (CoK; NFPA 1, 50.8.2.1): Yes **No**

Less than 10' from any MFVU or mobile/temp. cooking operations (NFPA 1, 50.8.2.2): Yes **No**

Less than 15' from any fire hydrant: Yes **No**

Located under building overhang, temporary structure, or in a parking garage: Yes **No**

Placement obstructs exit(s) for MFVU: Yes **No**

MFVU is stabilized from movement by jacks and/or wheel chocks around the wheels: **Yes** No

Obstructs Fire Dept Connection (FDC), Fire Protection Equipment (NFPA 1, 50.8.1.4): Yes **No**

Obstructs Fire Apparatus Access Road/Fire Lane (NFPA 1, 50.8.1.4): Yes **No**

Obstructs entrances/exits to any structure: Yes **No**

General location is unsafe (trip hazards, environmental conditions, wasps, etc.) Yes **No**

Will MFVU use tent(s) for temporary cooking operations? Yes **No**

If yes to tent(s) for temporary cooking operations (use additional Inspection Form):

1. Cooking operations in tents shall comply with NFPA 102, Chapter 25
2. Tent(s) more than 400 s.f. require a Tent Operational Permit from KFD (IFC, Section 105)

NOTE: This inspection form is for a site inspection, on proof of a Health Dept inspection within past 11 months and payment of City Vendor Permit.

MOBILE FOOD VEHICLE/VENDING UNIT (MFVU) Site Setup INSPECTION

Kyle Fire Department
Hays County Emergency Services District No. 5
210 West Moore Street, Kyle, TX 78640
(512) 268-3131 FAX (512) 268-6162

MFVU EXTERIOR

- Egress/Exit(s) from MFVU are clear of obstructions: **Yes** No
- Generator properly mounted or located at least 12' from MFVU (NFPA 1, 50.8.5): **Yes** No
- Generator exhaust pointed away from public, buildings, or MFVU openings: **Yes** No
- Generator in safe working condition & properly grounded: **Yes** No
- Generator refueled when ignition sources are off or generator is 20' from MFVU: **Yes** No
- Generator fuel kept in metal container UL or FM listed: **Yes** No N/A
- Spare LP/CNG cylinders/fuel cans kept 10' from MFVU, trash, combustibles (NFPA 30): **Yes** No

FUEL GAS COMPARTMENT / CYLINDER LOCATION

- LP/CNG Cylinders – **Quantity:** _____ **Size(s):** 20 30 40 100
- MFVU LP/CNG doesn't exceed 3 cylinders (CoK): **Yes** No
- MFVU LP/CNG capacity doesn't exceed a total of 200 gal (NFPA 1, 50.8.7.4.3.1)): **Yes** No
- Permanent CAUTION plate adjacent to LP/CNG cylinders* (NFPA 58) see below: **Yes** No

CAUTION:

- (1) BE SURE ALL APPLIANCE VALVES ARE CLOSED BEFORE OPENING CONTAINER VALVE.**
- (2) CONNECTIONS AT THE APPLIANCES, REGULATORS, AND CONTAINERS SHALL BE CHECKED PERIODICALLY FOR LEAKS WITH SOAPY WATER OR ITS EQUIVALENT.**
- (3) NEVER USE A MATCH OR FLAME TO CHECK FOR LEAKS.**
- (4) CONTAINER VALVES SHALL BE CLOSED WHEN EQUIPMENT IS NOT IN USE.**

- "NO SMOKING" sign posted at or near propane cylinders **Yes** No
- LP/CNG cylinders are properly mounted/secured and in upright position: **Yes** No
- LP/CNG cylinders are date stamped within 12 years (manufacture or recertification)*: **Yes** No
*7 years if the recertification date ends with an S, 5 years the recert date ends with an E.
- Compartment/Door/Covers properly labeled for LP/CNG & outside System Shut-off: **Yes** No
- Outside/Outside Storage Compartment LP/CNG shut-off accessible and operates*: **Yes** No
*Outside or compartment shut-off valve required for each cylinder, or system if approved manifold.
- Relief valve discharge within 3' of prohibited location*: Yes **No**
*Prohibited locations include within 3' from vehicle openings, gas fuel appliance intake or exhaust, internal combustion engine intake or exhaust terminations.

NOTE: This inspection form is for a site inspection, on proof of a Health Dept inspection within past 11 months and payment of City Vendor Permit.

MOBILE FOOD VEHICLE/VENDING UNIT (MFVU) Site Setup INSPECTION

Kyle Fire Department
Hays County Emergency Services District No. 5
210 West Moore Street, Kyle, TX 78640
(512) 268-3131 FAX (512) 268-6162

ELECTRICAL

- MFVU electrical supply cords rated for amps required to operate unit: **Yes** No N/A
- Permission obtained (in writing) for use of MFVU electrical supply cords **Yes** No N/A
- Extension cords used for permanent wiring or in prohibited locations*: Yes **No**
- *Prohibited locations include concealed in walls, floors, ceilings; running through doors, windows, cabinets; locations subject to damage; or where it would create a trip hazard.
- Breaker panel box(es) circuits are properly labeled: **Yes** No
- Electrical outlets/receptacles within 6' of water source, sink, faucet, hose bib, etc.: ... Yes **No**
- Exterior electrical wall outlets have proper in-use weather cover(s): **Yes** No
- Electrical complies with NFPA 70, National Electric Code: **Yes** No

FIRE AND LIFE SAFETY Initials

- Current address/location of MFVU posted and accessible to all employees: ... **Yes** No _____
- Employees have an approved method of communication to contact 9-1-1: **Yes** No _____
- Employees receive initial and annual training fire extinguishers & pull station: ... **Yes** No _____
- Employees receive initial and annual training on fuel-gas/fueling safety: **Yes** No N/A _____
- Exit doors clear of obstructions/door hardware operates properly: **Yes** No
- 2A10BC extinguisher conspicuously mounted inside with current inspection tag: **Yes** No
- Class K extinguisher (vegetable or animal fats/oils) mounted inside w/ current tag: **Yes** No
- Hood suppression system current tags at hood and pull station: **Yes** No N/A
- Hood suppression pull station accessible: **Yes** No N/A
- Audible alarm or visible indicator for activated hood (1 inside, 1 outside) **Yes** No N/A
- Hood suppression system cleaning certification: (Date: _____) **Yes** No N/A
- Carbon monoxide alarm present and tested: **Yes** No
- Propane/CNG combustible gas leak detector/alarm present and operating: **Yes** No

Inspection Result: **Approved** **Failed**

This Mobile Food Vehicle/Vending Unit (MFVU) has been inspected by the Kyle Fire Department. This statement of inspection in no way alleviates the responsibility of the owner, representative, or employees to comply with all ordinances and codes or stat and local laws. Code violations will NOT be approved by this department.

Date of Inspection: _____ Inspector: _____ Owner: _____

NOTE: This inspection form is for a site inspection, on proof of a Heath Dept inspection within past 11 months and payment of City Vendor Permit.